
## Forest fx


Forest fx represents the natural beauty and sophistication of wood in a practical and durable vinyl sheet format. The collection includes various wood designs with intricate grains and natural colourways.

The collection has been specifically developed for very heavy commercial installations including education, healthcare, office, retail and leisure sectors.



## PRODUCT SPECIFICATION







- The flooring shall incorporate a specially formulated polyurethane reinforcement, to significantly reduce maintenance costs.
- In accordance with EN ISO 10582/EN 649, the in-use classification must be at least 23/34/43 as described in EN ISO 10874: ie domestic areas with intense use; commercial areas with very heavy traffic; and heavy light industrial areas
- In respect of flame spread, the flooring shall have been fully tested to EN13501-1 and certified as having Class BfI-S1.
- The product must have been fully tested for abrasion resistance and meet the requirements of abrasion Group T, as defined in EN 649 and Binder Content Type 1 as defined in EN ISO 10582.
- · This product does not accumulate static charges above 2kV and is classified as 'antistatic' when tested to EN1815. For specialist applications where there is a requirement to dissipate the electrostatic charge see the Polyflor ESD product ranges.
- With regards the European requirements EN 13893 for slip resistance, the flooring shall be classified DS, making it suitable for use in areas which are predominantly dry. When tested to DIN 51130 the product shall be classified as R10. For safety flooring with sustainable wet slip resistance, refer to the
- In respect of light fastness, the flooring shall have been fully tested to EN ISO 105-B02 Method 3 as having a pass to ≥6.
- The flooring must be available in 2.01 metre width, including a 0.01 metre selvage for on site trimming, to minimise the number of joints.
- The flooring will achieve a BRE Global Environmental A+ rating ENP 415 in the Green Guide to Specification.
- · Generic EN 15804 Environmental Product Declaration (EPD) available on request.
- · The manufacturer should provide a facility to take back and recycle waste vinyl flooring material through the Recofloor scheme.
- The flooring shall be tested to and pass key independent, international standards for low VOC emissions.
- The product will achieve BES 6001 certification for responsible sourcing, obtaining a Very Good rating.
- The manufacturer of the floorcovering must be in possession of a valid quality systems certificate, showing compliance with BS EN ISO 9001. **\** 
  - The manufacturer of the floorcovering must be in possession of a valid environmental certificate, showing compliance with ISO 14001.
  - A moisture test must be carried out, to ensure that the subfloor has dried out to a level consistent with the application of vinyl flooring. The test should be carried out using a hygrometer, in accordance with the instructions in BS 8203. The result should not exceed 75%RH, once equilibrium has been achieved.
  - The adhesive used must be approved by Polyflor, to ensure full product compatibility.
  - · Products must be fully conditioned to the environment in which they are to be installed, as outlined by Polyflor.
  - · Installation must be carried out in accordance with BS 8203 and the instructions of Polyflor.
  - · All joints must be welded to produce hygienic, continuous floors.
  - Suitable for use with underfloor heating up to 27°C. See Polyflor Technical Information for details.
  - · For clarification and for information regarding handling and installation, adhesives, maintenance, applications and chemical resistance, consult Polyflor Customer Technical Services on +44 (0)161 767 1912, or email tech@polyflor.com.
  - At the date of issue the data presented is correct. However, Polyflor Ltd. reserve the right to make changes which do not adversely affect performance
  - · Variation in colour and design is a feature of these products intended to enhance the natural appearance of the floor.































